

JOINTS:

JOINTS SHALL BE PLACED AT 10' INTERVALS. JOINTS SHALL BE CUT VERTICALLY AND TO A DEPTH OF 5 INCHES.

APPROVED

City Engineer

11/29/04 Date CITY OF BELLINGHAM

EXTRUDED CEMENT CONCRETE CURB

DRAWING

CG-212