



NOTES:

1. DROP TEE TO BE INSTALLED MINIMUM OF 3' BELOW CONE SECTION.
2. INSIDE DROP MANHOLE SHALL BE INSTALLED ONLY WHERE APPROVED BY THE CITY.
3. SIZE OF MANHOLE WILL INCREASE WITH LARGER DIAMETER PIPE AND SHALL BE APPROVED BY THE ENGINEER.
4. CHANNEL TO OUTLET.

NO SCALE

APPROVED

Royl Routh
City Engineer

11/29/04
Date

CITY OF BELLINGHAM
INSIDE DROP SEWER
MANHOLE CONNECTION

DRAWING
SS-715