



**NOTES:**

1. UNLESS OTHERWISE INDICATED ON PLAN, SIDE SEWER SHALL BE A MIN. OF 6' DEEP AT PROPERTY LINE, OR 5' LOWER THAN THE LOWEST LOT ELEVATION, WHICHEVER IS LOWER.
2. WHEN REPLACING EXISTING SIDE SEWER, CONTRACTOR SHALL VERIFY POSITIVE FALL, OTHER EXISTING CONNECTIONS, AND SAGS OR DEFLECTIONS IN PIPE, AS PER ASTM F 1743 8.6.
3. INSTALL CLEANOUT AFTER 3 BENDS AND AT MAX 100' INTERVALS, ALSO AT END OF LINE, WITHIN 2' OF HOUSE.

NOT TO SCALE

APPROVED

*Ray Roberts*  
City Engineer

5/29/14  
Date

CITY OF BELLINGHAM  
SANITARY SIDE SEWER

DRAWING  
SS-730