

MEMORANDUM

To:

HEARING EXAMINER

From:

Brent Baldwin, Development Manager

Subject:

530 38TH STREET

Date:

May 25, 2023

Request

A variance to provide relief from constructing an alley in a platted right of way

Staff analysis

Bellingham Public Works Development Guidelines and Improvement Standards provides for a maximum grade of a public street at 15% grade. The applicant has submitted evidence that areas of the site exceed grades of 30% twice as steep as is allowable.

Recommendation

Staff agrees with the application for a variance due to topographical challenges and recommends that an approval to the variance be granted..



Bellingham Fire Department - Life Safety Division

June 7, 2023

MEMORANDUM

Bellingham Fire Department has no objection to VAR2023-0005 as proposed. The proposal will not require any infrastructure improvements to meet the fire code access requirements.

Shawn P. Linville #266 Division Chief/Fire Marshal Bellingham Fire Department